



Request for Proposal

ERICKSON WATER SYSTEM – METER PIT INSTALLATIONS PRJ24002

ADDENDUM NO. 2

Issued: April 16, 2025

Closing Date: 10:00am Local Time (PST), April 30, 2025

This Addendum shall be read in conjunction with and considered as an integral part of the Contract Documents; revisions supersede the information contained in the original specifications or previously issued Addendum. Price submitted shall include all items of this Addendum.

By this **Addendum No. 2**, dated April 16, 2025, the Request for Proposal documents for PRJ24002 shall be amended as specified below.

Questions & Answers:

Q1. Please provide pre-bid meeting sign-in sheet.

A1. Refer to Appendix A.

Q2. Please provide the service card spreadsheet referenced in Appendix B of the Request for Proposals.

A2. A copy of the services card spreadsheet has been emailed to contacts listed on the sign-in sheet. Contact Jeannine Bradley if you have not received this.

Q3. Can multiple pits be reviewed with RDCK operations staff prior to pre-construction meetings?

A3. This may be arranged in advance, subject to RDCK operations staff availability. A pre-construction meeting should still be scheduled for the day of mobilization, prior to commencing construction.

Q4. Should traffic control be included in unit pricing?

A4. Assume all traffic control equipment, materials and labour required to safely mobilize and work outside of the travelled portion of the highway is included in the unit price. Traffic control requiring lane closures may be included within force account. Contractor should include rates for typical traffic control equipment, material and labour Schedule C-2 of the bid form.

Q5. What extent of excavation should be included in unit pricing?

A5. Unit pricing for the meter pits should be based on excavating up to a volume of 3m x 3m x 1.5m (~5').

Q6. Who is responsible for testing the internal plumbing?

A6. RDCK will visually inspect connected plumbing for leaks. The contractor is responsible for arranging this inspection with RDCK operations staff prior to backfill. If the inspection is not completed before backfill, the contractor will be responsible for providing all equipment and labour to uncover and replace any leaking plumbing at their own cost.

Q7. Is weekend work permitted?

A7. Pre-arranged weekend work is permitted; however, the contractor is responsible for complying with all local bylaws (Town of Creston or RDCK as applicable), Ministry of Transportation and Transit requirements, and RDCK notice periods, meetings and inspections requirements. Note RDCK staff availability is limited on weekends.

Q8. Can clause relating to tariffs be negotiated (included in Schedule C-1 of the Request for Proposals)?

A8. The clause relating to tariffs has not been changed, as only a limited number of materials are expected to be at subject to potential tariffs.

Q9. How to present mark-up rates within bid form?

A9. Please present contractor mark-up rates for all materials not otherwise listed with a unit price within the materials table in Schedule C-2.

Q10. Can material lay-down areas be provided?

A10. Some lay-down may be pre-arranged at the RDCK locations listed in Item 5, Schedule 01 11 00 of the Request for Proposal.

Except as modified by Addendum No. 1 issued April 11, 2025 and this Addendum, the Request for Proposal documents for PRJ24002 shall remain unchanged.

Jeannine Bradley
Project Manager

- END OF DOCUMENT -

APPENDIX A: PRE-BID MEETING SIGN-IN SHEET



Meeting Sign-in

Project: Erickson Water Metering
Location: 1004 – 27th Ave S, Creston
Date: 15 April 2025

[illegible]