



Request for Quote

DUHAMEL WATER SYSTEM: WELL PUMP REPLACEMENT PRJ25029

ADDENDUM NO. 2

Issued: April 10, 2025

Closing Date: 2:00 pm Local Time, April 16, 2025

This Addendum shall be read in conjunction with and considered as an integral part of the Contract Documents; revisions supersede the information contained in the original specifications or previously issued Addendum. Price submitted shall include all items of this Addendum.

By this **Addendum No. 2**, the RFQ documents shall be amended as specified below.

Questions and Answers

Q1. What did you want to do with the existing 4" drop pipe? Leave onsite or have us dispose of it?

A1. The Contractor to dispose of the existing drop pipe once removed.

Q2. Can you please confirm the power coming in 208 volt 3 phase or 230v three phase.

A2. The power is 3 phase, 230V, 60hz.

Except as modified by Addendum No. 1 issued April 9, 2025, and this Addendum, the Request for Quote documents for PRJ25029 shall remain unchanged.

A handwritten signature in blue ink, appearing to read "AJ Evenson".

AJ Evenson

Senior Project Manager, Regional District of Central Kootenay

- END OF DOCUMENT -